



Snake Well House 5

The Setting

This Fact Sheet provides information about the Bushlight Household System installed at Snake Well. The system provides power for 1 house. This system was commissioned on the 19th May 2007.

Background

Snake Well, is situated North East of Alice Springs via Yambah Station. Prior to the Bushlight System being installed the community used 2 generators for power when diesel was available and when the generator was working. Estimated diesel cost per year is \$700.

Community Energy Planning Process

Bushlight has developed a participative approach to energy planning called the Community Energy Planning Model. Facilitated by regional Bushlight staff, this process assists householders to make informed decisions about their specific energy needs, including generation and consumption, which ultimately influences the most appropriate energy service options.

Basic Technical Information

The maximum daily AC load of the system is 7.5 kWh/day. There are no DC loads.

The following major components are used:

- PV array - roof mounted with a capacity of 2.40kWp
- Battery bank - Capacity of 1400Ah @ 24VDC providing 2 days of storage at 23% average daily depth of discharge
- Inverter – 1.5. kW @ 40°C
- Energy Management Units (EMU) - electricity metering and management devices that replace household switchboards.
- The total project cost was \$87,218. This included system mobilisation and installation, two service visits in the first year and additional works such as reticulation, installation of ceiling fans and replacing switchboards with EMUs. The Western Australian Government Renewable Energy Rebate Program provided a rebate of \$41,844.on the total cost.

Monthly Load Variations

The design load allows for the maximum daily power consumption to occur during the summer months when fridges and freezer are cycling more frequently and ceiling fan use is greater.

Demand Side Management

To minimise the risk of excessive power usage the following strategies have been implemented in consultation with the residents:

- An EMU has been installed at the house. The primary purpose of the EMU is to control the total load on the system, and ensure a fair and equitable distribution of power by providing each household with a predetermined amount of energy (the 'energy budget') each day.



Energy Management Unit

- Each EMU incorporates an intuitive user interface to aid energy management
- Low amp circuit breakers have been installed to prevent the usage of high power demand appliances
- Individual device timers have been installed for certain lights. The duration of these timers have been set to meet residents' needs
- Centrally controlled timers have been installed for light, fan and general power circuits. The duration of the timers have been set to meet residents' needs

In addition to the technical demand side management measures, Bushlight staff have facilitated a range of education and training activities to assist residents to manage their power consumption appropriately.

During pre-installation discussions residents agreed to use certain appliances, such as washing machines, only when there is enough power available. The best time to use them is in the morning, before the EMU resets the energy budget at midday.

Appliance Acquisition & Replacement

As part of the overall approach to demand side energy management, inefficient appliances are identified and replaced as the community is able to do so. At Snake Well 1 new efficient and appropriately sized fridge/freezer has been provided. Energy efficient lighting fixtures have also been fitted.

Generator Use

The existing generator was connected to the solar system to enable battery charging when the generator is running.

The following situations have been identified where the generator may need to be run:

- During extended periods of cloud cover
- When the community wishes to use power tools or kitchen appliances

Other Energy Services

In addition to the energy being supplied by the Bushlight Systems, the Snake Well residents continue to rely on the following additional energy sources:

- Firewood for cooking outside
- Gas for cooking inside
- Thermal solar hot water service

Contact Bushlight

Bushlight Administration
PO Box 8044, ALICE SPRINGS NT 0871
Tel (08) 8951 4311, Fax (08) 8951 4333
enquiries@bushlight.org.au